



AN ISO 9001 : 2008 COMPANY & NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 15/12/2018

Lab ID : CP-2018-12-03-05
Project Name : Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07
Agency : Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054
Customer's Reference : EE(Project)/Ynk Zone/wo/12/2018-19
Date of Receipt : 19-11-18
Customer ID : Pool Wall Concrete
Sample Type /Size : 150X150X150 mm
Sample grade/Age : M25 / 28 Days Compressive Strength
Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test : 15/12/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm ²)	Average Compressive Strength (N/mm ²)
1	Pool Wall Concrete	M25	17/11/2018	15/12/2018	149.19 X 151.47 X 149.51	22598	8.774	623.0	27.6	27.4
2	Pool Wall Concrete	M25	17/11/2018	15/12/2018	151.41 X 149.32 X 149.03	22609	8.817	600.1	26.5	
3	Pool Wall Concrete	M25	17/11/2018	15/12/2018	150.76 X 151.53 X 149.47	22843	8.213	641.5	28.1	

Asst. Executive Engineer
Project Division
Velahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager



Page 1/1
****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |



AN ISO 9001 : 2008 COMPANY & NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005

4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : CP-2018-12-03-05 Date: 01/12/2018

Project Name : Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07

Agency : Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054

Customer's Reference : EE(Project)/Ynk Zone/wo/12/2018-19

Date of Receipt : 26-11-18

Customer ID : Pool Wall Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M25 / 7 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 01/12/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm ²)	Average Compressive Strength (N/mm ²)
1	Pool Wall Concrete	M25	24/11/2018	01/12/2018	151.12 X 149.38 X 149.63	22574	8.101	519.5	23.0	22.5
2	Pool Wall Concrete	M25	24/11/2018	01/12/2018	151.42 X 149.89 X 151.37	22696	8.171	510.7	22.5	
3	Pool Wall Concrete	M25	24/11/2018	01/12/2018	151.50 X 150.63 X 149.73	22820	8.478	502.4	22.0	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager



Page 1/1

****End of Report****



AN ISO 9001 : 2008 COMPANY & NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 22/12/2018

Lab ID : CP-2018-12-03-05
Project Name : Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07
Agency : Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054
Customer's Reference : EE(Project)/Ynk Zone/wo/12/2018-19
Date of Receipt : 26-11-18
Customer ID : Pool Wall Concrete
Sample Type /Size : 150X150X150 mm
Sample grade/Age : M25 / 28 Days Compressive Strength
Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 22/12/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm ²)	Average Compressive Strength (N/mm ²)
1	Pool Wall Concrete	M25	24/11/2018	22/12/2018	149.66 X 149.75 X 151.30	22412	8.299	619.3	27.6	27.5
2	Pool Wall Concrete	M25	24/11/2018	22/12/2018	151.36 X 149.12 X 149.57	22571	8.564	603.1	26.7	
3	Pool Wall Concrete	M25	24/11/2018	22/12/2018	151.89 X 150.77 X 151.62	22901	8.384	641.8	28.0	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager



Page 1/1
****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |



AN ISO 9001 : 2008 COMPANY & NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 01/12/2018

Lab ID : CP-2018-12-03-05
Project Name : Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07
Agency : Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054
Customer's Reference : EE(Project)/Ynk Zone/wo/12/2018-19
Date of Receipt : 26-11-18
Customer ID : Pool Wall Concrete
Sample Type /Size : 150X150X150 mm
Sample grade/Age : M25 / 7 Days Compressive Strength
Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test : 01/12/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen	Cross sectional area	Weight of the sample	Failure Load	Compressive strength	Average Compressive Strength
					(mm)	(Sq.mm)	(kg)	(KN)	(N/mm ²)	(N/mm ²)
1	Pool Wall Concrete	M25	24/11/2018	01/12/2018	150.27 X	22603	8.401	525.2	23.2	22.5
					150.41 X					
					149.86					
2	Pool Wall Concrete	M25	24/11/2018	01/12/2018	150.94 X	22905	8.159	505.0	22.0	
					151.75 X					
					151.27					
3	Pool Wall Concrete	M25	24/11/2018	01/12/2018	151.26 X	22752	8.653	506.8	22.3	
					150.41 X					
					149.24					

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager



Page 1/1
****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |



AN ISO 9001 : 2008 COMPANY & NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 22/12/2018

Lab ID : CP-2018-12-03-05
Project Name : Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07
Agency : Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054
Customer's Reference : EE(Project)/Ynk Zone/wo/12/2018-19
Date of Receipt : 26-11-18
Customer ID : Pool Wall Concrete
Sample Type /Size : 150X150X150 mm
Sample grade/Age : M25 / 28 Days Compressive Strength
Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 22/12/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm ²)	Average Compressive Strength (N/mm ²)
1	Pool Wall Concrete	M25	24/11/2018	22/12/2018	151.58 X 151.77 X 151.40	23006	8.228	637.5	27.7	27.8
2	Pool Wall Concrete	M25	24/11/2018	22/12/2018	151.41 X 149.66 X 149.97	22660	8.433	606.2	26.8	
3	Pool Wall Concrete	M25	24/11/2018	22/12/2018	151.76 X 151.58 X 149.07	23003	8.831	662.3	28.8	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL PRO

KARTHIK RECHA
Authorized Signatory
Quality Manager



Page 1/1

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL
TECHNICAL PROJECT MANAGEMENT | SURVEYING SERVICES



AN ISO 9001 : 2008 COMPANY & NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 19/11/2018

Lab ID : CP-2018-12-03-05
Project Name : Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07
Agency : Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054
Customer's Reference : EE(Project)/Ynk Zone/wo/12/2018-19
Date of Receipt : 14-11-18
Customer ID : Balancing Tank Base Concrete
Sample Type /Size : 150X150X150 mm
Sample grade/Age : M25 / 7 Days Compressive Strength
Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test : 19/11/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm ²)	Average Compressive Strength (N/mm ²)
1	Balancing Tank Base Concrete	M25	12/11/2018	19/11/2018	151.60 X 149.05 X 151.21	22595	8.938	540.3	23.9	23.0
2	Balancing Tank Base Concrete	M25	12/11/2018	19/11/2018	149.18 X 151.26 X 151.90	22565	8.961	510.6	22.6	
3	Balancing Tank Base Concrete	M25	12/11/2018	19/11/2018	151.23 X 150.99 X 149.57	22834	8.729	514.7	22.5	

Asst. Executive Engineer
Project Division
Velahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1
****End of Report****



M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |



AN ISO 9001 : 2008 COMPANY & NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005

4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : CP-2018-12-03-05 Date: 10/12/2018

Project Name : Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07

Agency : Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054

Customer's Reference : EE(Project)/Ynk Zone/wo/12/2018-19

Date of Receipt : 14-11-18

Customer ID : Balancing Tank Base Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M25 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 10/12/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm ²)	Average Compressive Strength (N/mm ²)
1	Balancing Tank Base Concrete	M25	12/11/2018	10/12/2018	149.01 X 150.85 X 150.09	22478	8.115	625.0	27.8	27.4
2	Balancing Tank Base Concrete	M25	12/11/2018	10/12/2018	150.99 X 149.70 X 150.42	22603	8.132	593.0	26.2	
3	Balancing Tank Base Concrete	M25	12/11/2018	10/12/2018	149.21 X 149.14 X 150.24	22253	8.273	623.6	28.0	

ASCL Executive Engineer
Project Division
Velchenka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager



Page 1/1
****End of Report****



AN ISO 9001 : 2008 COMPANY & NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 19/11/2018

Sub ID : CP-2018-12-03-05
Project Name : Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07
Agency : Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054
Customer's Reference : EE(Project)/Ynk Zone/wo/12/2018-19
Date of Receipt : 14-11-18
Customer ID : Balancing Tank Base Concrete
Sample Type /Size : 150X150X150 mm
Sample grade/Age : M25 / 7 Days Compressive Strength
Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test : 19/11/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm ²)	Average Compressive Strength (N/mm ²)
1	Balancing Tank Base Concrete	M25	12/11/2018	19/11/2018	150.40 X 150.51 X 150.34	22637	8.717	538.6	23.8	23.1
2	Balancing Tank Base Concrete	M25	12/11/2018	19/11/2018	151.56 X 149.43 X 151.34	22647	8.769	507.7	22.4	
3	Balancing Tank Base Concrete	M25	12/11/2018	19/11/2018	149.65 X 150.57 X 150.62	22534	8.419	517.1	22.9	

Asst. Executive Engineer
Project Division
Velachanka Zone
Bangalore

FOR CIVIL Pro.

R. KARTHIK RECHAN
Authorized Signatory
Quality Manager



Page 1/1
****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |



TEST REPORT OF CEMENT CONCRETE CUBES

Date: 10/12/2018

Lab ID : CP-2018-12-03-05
Project Name : Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07
Agency : Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054
Customer's Reference : EE(Project)/Ynk Zone/wo/12/2018-19
Date of Receipt : 14-11-18
Customer ID : Balancing Tank Base Concrete
Sample Type /Size : 150X150X150 mm
Sample grade/Age : M25 / 28 Days Compressive Strength
Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 10/12/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm ²)	Average Compressive Strength (N/mm ²)
1	Balancing Tank Base Concrete	M25	12/11/2018	10/12/2018	151.84 X 150.23 X 150.32	22811	8.205	616.0	27.0	27.6
2	Balancing Tank Base Concrete	M25	12/11/2018	10/12/2018	150.62 X 150.05 X 151.06	22601	8.194	608.0	26.9	
3	Balancing Tank Base Concrete	M25	12/11/2018	10/12/2018	150.08 X 149.20 X 151.32	22393	8.132	649.2	29.0	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL PRO

R. KARTHIK RECHA

Authorized Signatory

Quality Manager



Page 1/1

****End of Report****



AN ISO 9001 : 2008 COMPANY & NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 19/11/2018

Job ID : CP-2018-12-03-05
Project Name : Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07
Agency : Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054
Customer's Reference : EE(Project)/Ynk Zone/wo/12/2018-19
Date of Receipt : 14-11-18
Customer ID : Balancing Tank Base Concrete
Sample Type /Size : 150X150X150 mm
Sample grade/Age : M25 / 7 Days Compressive Strength
Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 19/11/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm ²)	Average Compressive Strength (N/mm ²)
1	Balancing Tank Base Concrete	M25	12/11/2018	19/11/2018	150.12 X 150.19 X 150.87	22546	8.852	521.7	23.1	22.7
2	Balancing Tank Base Concrete	M25	12/11/2018	19/11/2018	151.28 X 150.51 X 150.09	22770	8.503	511.0	22.4	
3	Balancing Tank Base Concrete	M25	12/11/2018	19/11/2018	150.34 X 149.91 X 151.87	22538	8.146	505.9	22.4	

Asst. Executive Engineer
Project Division
Velahanka Zone
Bangalore

FOR CIVIL PRO

R KARTHIK RECHA
Authorized Signatory
Quality Manager



Page 1/1
****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |



AN ISO 9001 : 2008 COMPANY & NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 10/12/2018

Lab ID : CP-2018-12-03-05
Project Name : Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07
Agency : Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054
Customer's Reference : EE(Project)/Ynk Zone/wo/12/2018-19
Date of Receipt : 14-11-18
Customer ID : Balancing Tank Base Concrete
Sample Type /Size : 150X150X150 mm
Sample grade/Age : M25 / 28 Days Compressive Strength
Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test : 10/12/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm ²)	Average Compressive Strength (N/mm ²)
1	Balancing Tank Base Concrete	M25	12/11/2018	10/12/2018	151.04 X 149.14 X 149.51	22526	8.357	619.3	27.5	27.2
2	Balancing Tank Base Concrete	M25	12/11/2018	10/12/2018	150.46 X 150.88 X 150.23	22702	8.588	592.5	26.1	
3	Balancing Tank Base Concrete	M25	12/11/2018	10/12/2018	150.63 X 151.61 X 150.38	22837	8.397	641.2	28.1	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager



Page 1/1
****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL
TECHNICAL PROJECT MANAGEMENT | SURVEYING SERVICES |



AN ISO 9001 : 2008 COMPANY & NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 27/11/2018

Lab ID : CP-2018-12-03-05
Project Name : Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07
Agency : Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054
Customer's Reference : EE(Project)/Ynk Zone/wo/12/2018-19
Date of Receipt : 22-11-18
Customer ID : Balancing Tank Wall Concrete
Sample Type /Size : 150X150X150 mm
Sample grade/Age : M25 / 7 Days Compressive Strength
Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test : 27/11/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm ²)	Average Compressive Strength (N/mm ²)
1	Balancing Tank Wall Concrete	M25	20/11/2018	27/11/2018	151.63 X 151.05 X 150.85	22904	8.487	534.4	23.3	22.7
2	Balancing Tank Wall Concrete	M25	20/11/2018	27/11/2018	149.29 X 151.24 X 151.73	22579	8.479	507.3	22.5	
3	Balancing Tank Wall Concrete	M25	20/11/2018	27/11/2018	149.44 X 151.46 X 150.72	22634	8.100	507.7	22.4	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager



Page 1/1
****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL
MANAGEMENT | SURVEYING SERVICES |



AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 18/12/2018

Lab ID : CP-2018-12-03-05
Project Name : Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07
Agency : Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054
Customer's Reference : EE(Project)/Ynk Zone/wo/12/2018-19
Date of Receipt : 22-11-18
Customer ID : Balancing Tank Wall Concrete
Sample Type /Size : 150X150X150 mm
Sample grade/Age : M25 / 28 Days Compressive Strength
Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 18/12/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm ²)	Average Compressive Strength (N/mm ²)
1	Balancing Tank Wall Concrete	M25	20/11/2018	18/12/2018	151.73 X 151.24 X 150.34	22946	8.723	629.7	27.4	27.3
2	Balancing Tank Wall Concrete	M25	20/11/2018	18/12/2018	149.06 X 149.51 X 151.88	22285	8.727	581.6	26.1	
3	Balancing Tank Wall Concrete	M25	20/11/2018	18/12/2018	149.20 X 149.32 X 150.09	22279	8.846	633.7	28.4	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1
****End of Report****



M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |



AN ISO 9001 : 2008 COMPANY & NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 27/11/2018

Lab ID : CP-2018-12-03-05
Project Name : Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07
Agency : Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054
Customer's Reference : EE(Project)/Ynk Zone/wo/12/2018-19
Date of Receipt : 22-11-18
Customer ID : Balancing Tank Wall Concrete
Sample Type /Size : 150X150X150 mm
Sample grade/Age : M25 / 7 Days Compressive Strength
Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 27/11/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm ²)	Average Compressive Strength (N/mm ²)
1	Balancing Tank Wall Concrete	M25	20/11/2018	27/11/2018	149.16 X 150.43 X 151.71	22438	8.605	534.1	23.8	22.7
2	Balancing Tank Wall Concrete	M25	20/11/2018	27/11/2018	151.74 X 149.92 X 149.33	22748	8.537	504.3	22.2	
3	Balancing Tank Wall Concrete	M25	20/11/2018	27/11/2018	149.75 X 149.10 X 151.85	22327	8.767	493.4	22.1	

Asst. Executive Engineer
Project Division
Velahanka Zone
Bangalore

FOR CIVIL PRO.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager



Page 1/1
****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |



AN ISO 9001 : 2008 COMPANY & NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 18/12/2018

Lab ID : CP-2018-12-03-05
Project Name : Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07
Agency : Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054
Customer's Reference : EE(Project)/Ynk Zone/wo/12/2018-19
Date of Receipt : 22-11-18
Customer ID : Balancing Tank Wall Concrete
Sample Type /Size : 150X150X150 mm
Sample grade/Age : M25 / 28 Days Compressive Strength
Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test : 18/12/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm ²)	Average Compressive Strength (N/mm ²)
1	Balancing Tank Wall Concrete	M25	20/11/2018	18/12/2018	151.08 X 151.97 X 151.97	22960	8.312	628.6	27.4	27.4
2	Balancing Tank Wall Concrete	M25	20/11/2018	18/12/2018	149.43 X 149.76 X 149.27	22379	8.777	595.1	26.6	
3	Balancing Tank Wall Concrete	M25	20/11/2018	18/12/2018	150.29 X 150.59 X 149.92	22633	8.457	642.1	28.4	

Asst. Executive Engineer
Project Division
Velahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager



Page 1/1
****End of Report****



AN ISO 9001 : 2008 COMPANY & NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 06/12/2018

Lab ID : CP-2018-12-03-05
Project Name : Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07
Agency : Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054
Customer's Reference : EE(Project)/Ynk Zone/wo/12/2018-19
Date of Receipt : 01-12-18
Customer ID : Balancing Tank Wall Concrete
Sample Type /Size : 150X150X150 mm
Sample grade/Age : M25 / 7 Days Compressive Strength
Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 06/12/2018

SL. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm ²)	Average Compressive Strength (N/mm ²)
1	Balancing Tank Wall Concrete	M25	29/11/2018	06/12/2018	149.35 X 149.42 X 149.03	22315	8.929	526.0	23.6	22.8
2	Balancing Tank Wall Concrete	M25	29/11/2018	06/12/2018	150.60 X 151.74 X 150.39	22853	8.948	513.3	22.5	
3	Balancing Tank Wall Concrete	M25	29/11/2018	06/12/2018	150.96 X 150.40 X 149.95	22705	8.314	509.8	22.5	

Asst. Executive Engineer
Project Division
Velahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager



Page 1/1
****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |



AN ISO 9001 : 2008 COMPANY & NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 27/12/2018

Lab ID : CP-2018-12-03-05
Project Name : Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07
Agency : Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054
Customer's Reference : EE(Project)/Ynk Zone/wo/12/2018-19
Date of Receipt : 01-12-18
Customer ID : Balancing Tank Wall Concrete
Sample Type /Size : 150X150X150 mm
Sample grade/Age : M25 / 28 Days Compressive Strength
Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 27/12/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm ²)	Average Compressive Strength (N/mm ²)
1	Balancing Tank Wall Concrete	M25	29/11/2018	27/12/2018	150.59 X 149.24 X 149.96	22473	8.998	619.2	27.6	27.4
2	Balancing Tank Wall Concrete	M25	29/11/2018	27/12/2018	151.41 X 150.92 X 150.39	22850	8.345	606.0	26.5	
3	Balancing Tank Wall Concrete	M25	29/11/2018	27/12/2018	149.44 X 149.64 X 151.00	22362	8.742	632.3	28.3	

Asst. Executive Engineer
Project Division
Velachanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager



Page 1/1
****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL
PROJECT MANAGEMENT | SURVEYING SERVICES